

# Certificate of Compliance

Certificate Number 201206 - E303286  
Report Reference E303286, December 8th, 2006  
Issue Date 2006 December 20

Page 1 of 2



*Issued to:* **FAFNIR GMBH**  
BAHRENFELDER STR 19  
22765 HAMBURG GERMANY

*This is to certify that representative samples of*

**Associated Apparatus, Measuring Transducer**  
non-hazardous locations.

Model VISY Command, providing intrinsically safe outputs for use in Class I, Groups C and D hazardous locations when connected in accordance with Fafnir control drawing, drawing No. XF 020 00 15. See Addendum


*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* See Addendum for Standards

*Additional Information:*

ELECTRICAL RATINGS: The VISY Command is rated:  
Voltage 24V  
Frequency 50-60Hz  
Power consumption ;Ü2VA  
The ambient temperature 40°C

**Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: *Jasmin Omerovic*  
**Jasmin Omerovic, Associate Project Engineer**

UL International Demko A/S

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.  
For questions in Denmark, you may call +45 44856565.

Reviewed by: *Klaus M. Hansen*  
**Klaus M. Hansen, Senior Project Engineer**

UL International Demko A/S

# Certificate of Compliance

Certificate Number 201206 - E303286  
Report Reference E303286, December 8th, 2006  
Issue Date 2006 December 20

Page 2 of 2



**Underwriters  
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL, cUL requirements.

**Intrinsically safe apparatus, level sensor, hazardous locations.  
Class I, Groups C and D.**

**Model VISY Stick, intrinsically safe for use in Class I,  
Group C and D hazardous locations when connected in accordance  
with Fafnir installation wiring diagram, Drawing No. XF 020 00 15.**

**Standards:**

**UL 508 - Industrial Control Equipment**

**UL 913 - Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1,  
Hazardous (Classified) Locations**

**CSA C22.2 No. 142-M1987 - Process Control Equipment**

**CSA C22.2 NO. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations**

Issued by: *Jasmin Omerovic*  
**Jasmin Omerovic, Associate Project Engineer**

UL International Demko A/S

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.

Reviewed by: *Klaus M. Hansen*  
**Klaus M. Hansen, Senior Project Engineer**

UL International Demko A/S